



EXPLANATIONS

1. After assembling the system, connect the free pole of the battery to the system
2. The system is designed to give 12VDC output at any case, whether there is line voltage or not
3. Even if there is no line voltage, alarm and ding-dong perform their functions.
4. After line voltage is cut off, emergency light is on during next 12 minutes. After turning off, if one pushes the help button, it becomes on again.
5. The battery of the system can feed the emergency lamp during 3 hours.

F/7.5.5.02.69

This document is a sample for applications. All information contained in these materials are subject to change by Aybey Elektronik without notice. Aybey Elektronik assumes no responsibility for any damage, liability, or other loss rising from these inaccuracies or errors.

INSPECTION BOX				
AYBEY ELEKTRONIK	SERIES	ACT	DRW.	M. AKKUŞ
	PROJ.	ACT051	APPRV.	M. AYBEY
	REV.	04	DATE	15 MAY 13